NISTIR 6527

Measurement Needs for Fire Safety: Proceedings of an International Workshop

Thomas J. Ohlemiller Erik L. Johnsson Richard G. Gann



Measurement Needs for Fire Safety: Proceedings of an International Workshop

Thomas J. Ohlemiller
Erik L. Johnsson
Richard G. Gann
Building and Fire Research Laboratory
National Institute of Standards and Technology
Gaithersburg, MD 20899-8653

June 2000



U.S. Department of Commerce William M. Daley, Secretary

Technology Administration

Dr. Cheryl L. Shavers, Under Secretary of

Commerce for Technology

National Institute of Standards and Technology Raymond G. Kammer. Director

NOTICES:

Works of authors who are not staff members of NIST are provided for information purposes.

NIST is not responsible for their content.

The identification of any commercial product or trade name does not imply endorsement or recommendation by the National Institute of Standards and Technology, nor is it intended to imply that the product identified is necessarily the best available for the purpose.



Smoke gas analysis by Fourier transform infrared spectroscopy

Contract no. SMT4-CT96-2136

Final report of the SAFIR project

Edited by Tuula Hakkarainen, VTT Building Technology



Accuracy of FTIR: Interlaboratory trail

Method / parameters	Repeatability standard deviation <i>s</i> ,/ <i>m</i>	Reproducibility standard deviation s_R/m
SBI, 1997 RHR _{max} , THR	5 - 41 %	7 - 60 %
Smoke prod.	7 - 78 %	19 - 114 %
Cone calorimeter, 1997		
RHR _{max} , THR	3 - 55 %	4 - 87 %
Cone calorimeter, 1991-2		
Smoke prod.	6 - 60 %	16 - 100%
This study		
Max gas conc.	4 - 17 %	15 - 47 %
Gas yield (FTIR)	(11,0 % average)	(27,9 % average)
RHR _{max} , THR	4 - 16 %	10 - 34 %
Smoke prod.	4 - 14 %	9 - 18 %



Summary

- Sampling is critical
- A number of measurement methods exists
- GC/MS, MS: organic species, small to large
- FTIR: inorganic species, smaller organics
- Low detection limits □ longer measurement time

